

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1574:157

Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield, NJ, 07004-1561
Contact: Ron Dalton (310) 725-2972 FAX (310) 725-2942

DESIGN: Models "Focus 200" 472362 and 472363; "Focus 200B" 472362B fire alarm control units. Power-limited; local, manual, automatic, proprietary, remote station and central station and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

472362, 472362B, 472363	Control Unit
472368	SIM Gateway
248239	PID Gateway
471715	Printer Interface
248259	Battery Cutoff Module
472398, 472399	Communication Module
471210	Keypad
472372	Power Supply
472366	Interface Module
472381	Auxiliary Power Supply
472364, 443219	Transformer
471877	Quad PID Module
471941	Micro PID Module
471943	Micro PID Housing
472388	Horn/Strobe SIM

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL Inc. Label

APPROVAL: Listed as a fire alarm control unit for use with separately listed electrically compatible initiating and indicating devices. This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: 1. Model Focus 200 control units are a revision of and operate similar to listed Model Focus 100 (CSFM Listing No. 7165-1574:149). For additional accessories, refer to the Focus 100 listing.

2. Formerly 7165-0085:171

05-20-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 23, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager